



ASSESSORS

of the

**Materialprüfungs- und Versuchsanstalt
Neuwied GmbH**

Forschungsinstitut für vulkanische Baustoffe

Approved testing, monitoring and certification
organisation under construction supervisory
law

Approved monitoring organisation in
accordance to DIN 1045-3

Approved under civil law in compliance with
"RAP Stra"

Abstract of the results of expertise No.: 600554/09

Applicant:

SEVES S.p.A.

Via Reginaldo Giuliani 360

Firenze-Italy

Object of application:

**Determination of thermal transmittance (U-value) of a
Glass Block Wall**




Figure 1: Isothermal lines Glass Block Wall Type 1919/8 Energy Saving Glass Block

| λ_{eq} [W/(m*K)] | U value [W/(m ² *K)] | U value, rounded [W/(m ² *K)] |
|--------------------------|---------------------------------|--|
| 0,163 | 1,517 | 1,5 |

Table 1: Results Glass Block Wall Type 1919/8 Energy Saving Glass Block

Date: 5. May 2009

This summary of the results is only an overview. For further use only the sealed full report no.: 600554/09 is legal. The test report shall not be reproduced in any abridged form, in extracts, or for advertising purposes unless this Institute has given its prior written consent. This test report is a translation of a German test report. In cases of doubt only the German version is relevant.

I:\60_0554_solaris\0554gc_solaris.doc